



1000 Carthage Street
P.O. Box 636
Sanford, NC 27331
919-776-7655
www.sanfordhousingauthority.org

For Flooring Installation Services for
The Sanford Housing Authority
RFP #15-010
Addendum #2

1. On Proposal #15-010 are you wanting VCT put back everywhere in all spaces listed? Or are you wanting carpet put back where it states currently comprised of carpet & tile which would be the Wilrik Stewart Manor, & Crestview.

Response: Some locations, such as the Wilrik, contain carpet and tile. A location containing carpet now, such as Stewart Manor, may be replaced with tile.

2. Asbestos Tile is mentioned. We cannot demo or dispose of Asbestos Tile or do any sanding. All we can do is cover and contain. We do have sources to get pricing for removal if you wish, but it is very costly. Just wanting to make sure if indeed there is asbestos tile that will need to be dealt with on this project somewhere or if this is a coverall statement.

Response: This is an overall statement. If asbestos tile is present and will be replaced, it must be handled properly.

Shannon McLean
Name/Title *Executive Director*

5-27-15
Date